

# CERTIFICATE

Issued to:  
Applicant:  
**OBO Bettermann Hungary Kft.**  
**Alsorada 2**  
**2347 Bugyi, Hungary**

Licensee:  
**OBO Bettermann Hungary Kft.**  
**Alsorada 2**  
**2347 Bugyi, Hungary**

Product : Socket-outlet (2-pole, with earthing) for fixed installation  
Trade name(s) : OBO  
Type(s)/model(s) : SKS-DK0 Series

The product and any acceptable variation thereto as specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to IEC 60884-1:2002, IEC 60884-1:2002/AMD1:2006, IEC 60884-1:2002/AMD2:2013 and DS 60884-2-D1:2017
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6062103


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 6 July 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-129318

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



C. Lin  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Socket-outlet (2-pole, with earthing) for fixed installation
Trade name(s)	: OBO
Type(s)/model(s)	: SKS-DK0 Series
Method of mounting	: flush-type
Rated current	: 13 A
Rated voltage	: 250 V~
Design	: rewirable, with shutters
Standard sheet	: DKA 1-1b of DS 60884-2-D1:2017
Terminals	: screw-type terminals
Description	: body of thermoplastic material

**TESTS****Test requirements**

IEC 60884-1:2002  
IEC 60884-1:2002/AMD1:2006  
IEC 60884-1:2002/AMD2:2013  
DS 60884-2-D1:2017

**Test result**

The test results are laid down in DEKRA test file 490386900.

**Additional information**

Name of product principle:

SKS-DK0 Series: SKS-DK0 RW1, SKS-DK0 SWGR1, SKS-DK0 SRO1, SKS-DK0 ROR1, SKS-DK0 MZGN1

SKS-DK0, basic model name

RW1: white cover

SWGR1: black cover

SRO1: red cover

ROR1: orange cover

MZGN1: green cover

All models are same except the colour.

The list of components is laid down in test report 4903869.50.

**Conclusion**

The examination proved that all requirements were met.

**Factory location**

Zhejiang Sino Electro-technical Co., Ltd .  
A5 Building, Sulv Industrial Zoen, Yueqing City,  
325604 Wenzhou Zhejiang, China